

## City of Manchester Fire Department

100 Merrimack Street • Manchester, New Hampshire 03101-2208 (603) 669-2256 – Business • (603) 665-6802 – Fax www.ci.manchester.nh.us

Joseph P. Kane Chief of Department

## FIRE PREVENTION AND SAFETY COMPLIANCE STANDARD 2007-3-1

DATE: 8 June 2007

REGARDING: OUTDOOR COOKING

DETAILS: (Description of specific

orders to be followed)



COOKING ON PORCHES OR BALCONIES SHALL BE <u>PROHIBITED</u> IN THE CITY OF MANCHESTER, NH.

THERE SHALL BE NO OUTDOOR COOKING OR STORAGE OF LP-GAS CONTAINERS WITHIN TEN (10) FEET OF ANY STRUCTURE. THERE SHALL BE NO EXCEPTIONS TO THIS STANDARD.

CODE OF ORDINANCE REFERENCE: <u>CITY OF MANCHESTER CODE OF ORDINANCE</u> SECTION 92.05, <u>INTERNATIONAL FIRE CODE 2000 ED</u> SECTION 307.5, 307.5.1.

| Joseph P. Kane,<br>Chief of Department | James A. Burkush, Chief of Fire Prevention |
|--|--|